



GREATER VISAKHAPATNAM MUNICIPAL CORPORATION
FIRE PREVENTION WING

From:
 The Commissioner,
 Greater Visakhapatnam
 Municipal Corporation,
 Visakhapatnam.

To:
 The District Educational Officer,
 Visakhapatnam District,
 Visakhapatnam.

Rc.No.209/RFO/FPW/GVMC/2022, Dt.30/07/2025

SUB: Greater Visakhapatnam Municipal Corporation – Fire Prevention Wing-
 Existing Building of **M/s.Sri Satya Sai Vidya Vihar, D.No.1-109-12, Sector-8, MVP Colony, Visakhapatnam – Renewal of Fire No Objection Certificate** – Issued - Regarding.

- REF:** 1. Letter Rc.No:5041/B2/97 of Director General, A.P.Disaster Response & Fire Services Department, Dated: 12-03-2010.
 2. Delegation orders of the Commissioner, GVMC vide Rc.No.6721/2012/TP. Sec/G1 Dt:13/09/2019.
 3. This office Fire No Objection Certificate for Occupancy issued vide Rc.No.009789/RFO/ FPW/GVMC, Dt.25-02-2020.
 4. This office Renewal of Fire No Objection Certificate issued vide Rc.No.243/RFO/FPW/GVMC/2022, Dt.16-06-2022.
 5. Application Dated: 27-07-2025 of M/s.Sri Satya Sai Vidya Vihar, D.No.1-109-12, Sector-8, MVP Colony, Visakhapatnam for Renewal of Fire NOC.

*** **

It is to inform that vide reference 3rd cited, Fire No Objection Certificate for Occupancy was issued to M/s.Sri Satya Sai Vidya Vihar, D.No.1-109-12, Sector-8, MVP Colony, Visakhapatnam and vide reference 4th cited, the management obtained Renewal of Fire No Objection Certificate.

2) Vide reference 5th cited, an application is received by this office for issuance of Renewal of Fire No Objection Certificate to the same building.

3) Therefore, the Inspection Committee of District Fire Officer and Station Fire Officer of Fire Prevention Wing inspected the premises of M/s.Sri Satya Sai Vidya Vihar, D.No.1-109-12, Sector-8, MVP Colony, Visakhapatnam on 29-07-2025 and submitted the following report.

4) Particulars of The building:

a)	Address of the Premises	M/s.Sri Satya Sai Vidya Vihar, D.No.1-109-12, Sector-8, MVP Colony, Visakhapatnam
b)	Total Plot Area	5700.99 Sq. Mtrs.
c)	Height of the Building	14.00 Mtrs.
d)	No of blocks/ floors	01 / Ground + 03 Upper Floors
e)	Type of occupancy	Educational (School)

5) Floor wise details:

Sl. No	Floor	Area in Sq. Meters.				Total	Type of Occupancy
		Circle Block	L-Block	Books Block	Prayer Minder Block		
1	Ground	1154.0	620.60	85.21	555.00	2414.8	Educational
	8					9	

Contd..page..2



:: 2 ::

2	First	1154.0 8	620.60	98.36	—	1873.0 4	Educational
3	Second	—	620.60	98.36	—	718.96	Educational
4	Third	—	620.60	—	—	620.60	Educational
	Total	2308.1 6	2482.40	281.93	555.00	5627.4 9	

6) The Builder has provided the following Existing open places for all Blocks as below:

Direction	Existing Open space			
	Circle Block	L-Block	Books Block	Prayer Minder Block
West	01.08 Mtrs. to 02.30 Mtrs.	02.00 Mtrs.	06.00 Mtrs.	06.00 Mtrs.
East (Front)	04.61	05.60 Mtrs.	02.00 Mtrs.	03.42 Mtrs.
North	02.79 Mtrs	04.00 Mtrs.	02.00 Mtrs.	03.42 Mtrs.
South	04.00 Mtrs	06.00 Mtrs.	02.00 Mtrs.	06.00 Mtrs.

7) Means of Escape:

- Circle Block
 - Two Internal Staircases with a width of 01.45 Mtrs. each
- L-Block.
 - One Internal Staircase with a width of 01.25 Mtrs. and one External staircase with a width of 01.25 Mtrs.
- Book Block.
 - One external staircase with a width of 02.50 Mtrs.

8) The Minimum Fire Safety Installations required & provided by the Builder as per the Table 7 of Part-4 of N.B.C of India 2016 for all blocks.

Sl. No.	Fire Safety Measures	Required	Provided	Deficit
1.	Fire Extinguishers as per IS 2190	25 Nos.	25 Nos.	Nil
2.	Hose Reel with Landing Valve with Hose Box	01 No in each Floor	01 No in each Floor	Nil
3.	Down Comer	01 No	01 No.	Nil
4.	Manually Operated Electronic Fire Alarm System	02 Nos. in each floor	02 Nos. in each floor	Nil
5.	Terrace Tank	20,000 Ltrs	20,000 Ltrs	Nil
6.	Booster Pump of 900 LPM	Required	Provided	Nil
7.	Two way Fire Brigade Inlet	Required	Provided	Nil

9) The management has remitted an amount of Rs.84,420/- vide challan No.2025-CH-03508, Dt.25-07-2025 towards fire precautionary fees for 03 years period.

10) The Fire safety systems were tested by the Inspection Committee, Fire Prevention Wing, GVMC during the inspection and performance found satisfactory and recommended for issuance of Renewal of Fire No Objection Certificate.

11) Therefore, **Renewal of Fire No Objection Certificate** is hereby issued to M/s. Sri Sanya Sai Vidya Vihar, D.No.1-109-12, Sector-8, MVP Colony, Visakhapatnam subject to the following conditions:



Contd..page..3

:: 3 ::

i.	All the protection arrangements shall be maintained in good condition as seen during inspection
ii.	All the escape / exit routes shall not be kept locked / blocked or encroached
iii.	All the occupants must know the correct method of operation of the fire fighting system installed
iv.	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibility of the management.
v.	All students / staff members of the institution shall be trained to operate the fire safety equipments during Emergency.
vi.	Addition / alteration, if any in the building may be obtained with prior permission from this department.
vii.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.

13) The **Renewal of Fire No Objection Certificate** issued to M/s.Sri Satya Sai Vidya Vihar, D.No.1-109-12, Sector-8, MVP Colony, Visakhapatnam **is valid from 03-08-2025 to 02-08-2028** and the Management shall submit the application for Renewal of Fire No Objection Certificate two (2) months before the date of expiry.

13) The issuing of Fire NOC is without any prejudice to take action by GVMC against Unauthorized Construction, if any made.


 (CH.KRUPAVARAM)
 Regional Fire Officer I/c.
 Fire Prevention Wing,
 Greater Visakhapatnam Municipal Corporation,
 Visakhapatnam



Digitally signed by
CHINTADA KRUPAVARAM
Date: 30-07-2025
13:40:35